



STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF UNDERGROUND STORAGE TANKS
WRS TENNESSEE TOWER
312 Rosa L. Parks Ave., 12th Floor
NASHVILLE, TENNESSEE 37243

Daily Record of Visual Inspection for Incompatible Dispenser Components

Dispensers that are **not** certified by the manufacturer or UL Marked as E-Blend compatible (greater than 10% Ethanol) may be used with E-Blend fuel if a daily visual inspection is conducted by the owner/operator or someone authorized by the owner/operator. The components below must be visually inspected daily for leaks and failures. Any component that leaks or does not operate as designed must be replaced with a compatible component. **Contact the Division immediately if you observe a leak or failure.** Record inspections on this form and retain these records for 1 year. Keep this record on site or available for submittal to the Division within 72 hours. **If a leak is found, write LEAK in the box. For no leak, put an X in the box.**

Facility# _____ Month _____ Year _____

Day	Seals/ Gaskets	Filter	Suction Pump	Hoses	Meter	Break away	Nozzle/ Swivel	Dispenser Sump Dry? Y/N	Pipe Joints	Flex Connector	Shear Valve	Check Valve	Inspector
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30													
31													

COMMENTS